

DÉCLARATION DE CONFORMITÉ

n° 0110/A


DECLARATION OF CONFORMITY

Nous déclarons que le(s) produit(s) :
 We declare that the product(s) :

Chemins de câbles / Cable trays P31 H100, PG-HDG

| LENGTHS OF PERFORATED METAL CABLE TRAY | | | |
|---|---|---|---------|
| Male / female coupling system cable trays | Traditional coupling cable trays 1.2/1.5 mm thick | Traditional coupling cable trays 2 mm thick | |
| | | | |
| | | L = 3 m | L = 6 m |
| LENGTHS OF BLIND METAL CABLE TRAYS | | | |
| Male / female coupling system cable trays | Traditional coupling cable trays 1.2/1.5 mm thick | Traditional coupling cable trays 2 mm thick | COVERS |
| | | | |

Eclissages / Joints :



| Pack | Cat.Nos | Designation |
|------|----------|---|
| | PG | HDG |
| 1 | 4 802 26 | 4 832 26 EDU coupler |
| 1 | 3 412 16 | 3 432 16 EP coupler |
| 1 | 3 412 20 | 3 432 20 ER coupler |
| 1 | 4 874 77 | 4 874 79 External bracket coupler for P31, 1.2/1.5 and 2 mm thick |

est(sont) conforme(s) à CEI 61537 (10-2006) Système de chemin de câbles
 is (are) comply with IEC 61537 (10-2006) Cable tray systems

§11.1 Continuité électrique / Electrical continuity

Eclissage / joint < 50 mΩ

Chemin de cable / cable tray < 5 mΩ/m

Montbard, le 28/11/2018

Page 1/1

Jean Luc Chartier
 Laboratory manager